



8820 Old Hwy 99 SE, Olympia, Washington 98501, USA  
360-943-6063 8000-562-6184 FAX 360-352-4813 www.ch2o.com



# 6438 HYDRO-TREAT HYDRONIC LOOP TREATMENT

### APPLICATION

CH<sub>2</sub>O HYDRO-TREAT products are designed to reduce iron and copper corrosion related to oxygen attack in closed loop hydronic systems. While no water treatment product can repair corrosion damage once it has occurred, continuous treatment can extend equipment life.

HYDRO-TREAT performance is dependant upon system operation, design, cleanliness, metallurgy, leaks, and water chemistry. For optimal results, the following actions should be taken by operational personnel:

- Precleaning to prepare system for treatment;
- Routine inspection to ensure no ingress of oxygen;
- Periodic biological testing and addition of biocides;<sup>1</sup>
- Daily testing and recording of chemical residuals.

If problems are encountered maintaining product residuals, additional analytical testing may be required. At your request a CH<sub>2</sub>O water treatment specialist may assist in performing these services.

Product **6438** contains a blended nitrite and borate base. This combination gives excellent performance in many systems. This product is compatible with many glycol antifreeze solutions.

<sup>1</sup> Cooling Water Treatment Principles & Practice, Colin Frayne

### SAFETY & HANDLING PROCEDURE

This product is a mildly alkaline material. It is not considered hazardous, however, it is recommended that safe handling procedure associated with industrial chemicals of this type be practiced.

### DOSAGE

Charge the system at the rate of 7.7 gallons per 1,000 gallons of water.

### FEEDING TECHNIQUE

Inject directly into the system or add via a bypass feeder.

### CONTROL

Maintain a residual of 800 to 1,200 parts per million Sodium Nitrite (NaNO<sub>2</sub>), using CH<sub>2</sub>O's **LNT-40** test kit. Consult your CH<sub>2</sub>O water treatment specialist for further information on testing. Daily testing is recommended to maintain proper control. Failure to monitor and maintain treatment levels can cause damage. It is the customer's responsibility to monitor and maintain treatment levels.

### PHYSICAL PROPERTIES

|                          |              |
|--------------------------|--------------|
| pH of 1% Solution.....   | 8.0-10.0     |
| Pounds per Gallon.....   | 9.0-9.5      |
| Physical Appearance..... | Clear Liquid |
| Odor.....                | Mild         |
| Flash Point.....         | NA           |

### **Seller Warranty**

Applies to all products sold by CH<sub>2</sub>O, Inc., and is hereby communicated to all of its customers as a condition of sale.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the directions for use when used in accordance with the directions under normal conditions. Buyer assumes the risk of any use contrary to such directions. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including **NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE**. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

June 25, 2003 (Rev 09-11)

