



8820 Old Hwy 99 SE, Tumwater, Washington 98501, USA  
360-943-6063 8000-562-6184 FAX 360-352-4813 www.ch2o.com



# 6201 BOILER WATER TREATMENT LOW PRESSURE

### APPLICATION

Natural water contains gasses and minerals that can cause corrosion and deposit formation in steam boiler systems. This leads to loss of efficiency and damage from leakage or overheating. CH<sub>2</sub>O Boiler Treatment Products are designed to reduce many of the inherent problems associated with steam boiler applications.

No chemical product can completely eliminate water-related problems; results are dependent on several factors including maintaining proper chemical residuals, system operation, design, cleanliness, metallurgy, and water quality. For optimal results the following actions should be taken by qualified operational personnel:

- Initial system cleaning and passivation.
- Maintaining feedwater free of contaminants and particulate matter.
- Insuring proper chemical feed rates and system blow-downs.
- Verifying proper operation of chemical control and pretreatment equipment.
- Daily testing and recording of chemical residuals.

If problems are encountered maintaining product residuals, additional analytical testing may be required. At your request a CH<sub>2</sub>O representative may assist in performing these services.

Product **6201** is a one-drum boiler compound that is indicated for use when corrosion is the primary concern. The product incorporates a mild **POSCA** inhibitor control program with nitrite-based corrosion inhibitors. It is well suited for low to moderate alkalinity feedwater and high-condensate return applications. This product should not be used in combination with volatilizing amines. If additional condensate corrosion inhibition is required, alternate products are available.

### SAFETY & HANDLING PROCEDURE

This product is a low to moderate alkaline material. It is not considered hazardous; however, it is recommended that safe handling procedure associated with industrial chemicals of this type be practiced.

### DOSAGE

Initially charge the system at the rate of 1.5 to 2 quarts per 100 gallons of boiler water.

### FEEDING TECHNIQUE

Inject directly into the system or add via a by-pass feeder. It can also be added to a chemical feed tank.

### CONTROL

Maintain a residual of 400 to 800 parts per million as Sodium Nitrite (NaNO<sub>2</sub>), in the system at all times using CH<sub>2</sub>O's **LNT-25** test kit. Consult your CH<sub>2</sub>O representative for further information on testing. Daily testing is necessary for best results and is recommended to maintain proper control. Failure to monitor and maintain treatment levels can cause damage. It is the customer's responsibility to monitor and maintain treatment levels.

### PHYSICAL PROPERTIES

pH of 1% Solution .....	11.0-12.5
Pounds per Gallon .....	9.4-9.9
Physical Appearance .....	Tan Liquid
Odor .....	Mild
Flash Point .....	NA

### Seller Warranty

CH<sub>2</sub>O brand test reagent refills are available through your sales representative at no charge. Customers are required to confirm product compatibility via a control test for their specific application. CH<sub>2</sub>O recommends that you perform regular/daily testing to control chemical levels and cycles of concentration within established limits. Additional tests may be performed at your request. Test reports reflect conditions at the point when the analysis was performed. Results will change over time and with varying operating conditions.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the directions for use when used in accordance with the directions under normal conditions. Buyer assumes the risk of any use contrary to such directions. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

Applies to all products sold by CH<sub>2</sub>O, Inc., and is hereby communicated to all of its customers as a condition of sale. Use of CH<sub>2</sub>O products is subject to the Standard Terms and Conditions as listed on CH<sub>2</sub>O, Inc.'s website at: [www.ch2o.com](http://www.ch2o.com).

