



8820 Old Hwy 99 SE, Tumwater, Washington 98501, USA
 360-943-6063 800-562-6184 FAX 360-352-4813 www.ch2o.com

**Public
 OEM
 Bulletin**

AGRISYSTEM 2 (BRONZE)



HISTORY

The AgriSystem 2 (Bronze) has been designed to efficiently deliver our proprietary combination of CH₂O, Inc. products listed in the PRODUCTS table. Review associated product bulletins for more details on specific products at www.CH₂O.com.

OPERATIONAL CONSIDERATIONS

Electric Needs: 110V 15 AMP electrical outlet
 Unit Dimensions: 2'wide x 3' high

The AgriSystem 2 (Bronze) comes equipped with a fused electrical box, annual preventative maintenance kit, and your choice of low flow, medium flow, or high flow pumps based on GPM requirements. This is considered a manual unit; available with clear indoor or dark outdoor cover; and is available with poly stand.

INDUSTRIES

Field Irrigation	Drip Irrigation
Dump Tanks	Spray Bar

TYPICAL APPLICATIONS

Clean and Flush	Drip Irrigation
Irrigation Lines	Emitters

PRODUCTS

Activator C	Activator CH
Activator H	Clean Finish
Color Guard	Emitter Clear
Organic Emitter Clear	Sure Flow F
Sure Flow FA	Sure Flow NS

TESTING REQUIREMENTS

Testing requirements: pH, Chlorine Dioxide, Total Oxidants, and ORP. A control test is necessary on individual plant species and/or applications to determine tolerance. Customers shall set treatment levels based on their control test results. Daily testing is recommended to maintain desired level control. It is the customer's responsibility to monitor and maintain treatment levels. Failure to monitor and maintain treatment levels can cause damage. Use only CH₂O, Inc. OEM equipment with CH₂O, Inc. products.

PREVENTATIVE MAINTENANCE (PM)

ITEM	FREQUENCY
Pumps	Yearly head replacement
Check Valves	Every 6 – 12 months
Back Pressure Valves	Inspected every visit, replaced as needed.
Pressure Valves	Inspected every visit, replaced as needed

Seller Warranty

CH₂O brand test reagent refills are available through your sales representative at no charge. Customers are required to confirm product compatibility via a control test for their specific application. CH₂O recommends that you perform regular/daily testing to control chemical levels and cycles of concentration within established limits. Additional tests may be performed at your request. Test reports reflect conditions at the point when the analysis was performed. Results will change over time and with varying operating conditions.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the directions for use when used in accordance with the directions under normal conditions. Buyer assumes the risk of any use contrary to such directions. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

Applies to all products sold by CH₂O, Inc., and is hereby communicated to all of its customers as a condition of sale. Use of CH₂O products is subject to the Standard Terms and Conditions as listed on CH₂O, Inc.'s website at: www.ch2o.com.



VERSION DATE: December 12, 2016 REVISION DATE: June 13, 2017

