



8820 Old Hwy 99 SE, Tumwater, Washington 98501, USA  
 360-943-6063 800-562-6184 FAX 360-352-4813 www.ch2o.com

**Public  
 OEM  
 Bulletin**

## AgriSystem (Silver)



### HISTORY

The AgriSystem (Silver) has been designed to efficiently deliver CH<sub>2</sub>O, Inc. products listed in the PRODUCTS table. Review associated product bulletins for more details on specific products at www.ch2o.com.

### OPERATIONAL CONSIDERATIONS

Electric Needs: 110V 15A electrical outlet  
 Unit Dimensions: 2x2 feet

The AgriSystem (Silver) comes equipped with preventative maintenance kit, pump, controller, and injection assembly.

### TESTING REQUIREMENTS

Testing requirements to ensure desired residuals are being maintained will need to be identified by customer application.

A control test is necessary on individual plant species and/or applications to determine tolerance. Customers shall set treatment levels based on their control test results. Daily testing is recommended to maintain desired level control. It is the customer's responsibility to monitor and maintain treatment levels. Failure to monitor and maintain treatment levels can cause damage. Use only CH<sub>2</sub>O, Inc. OEM equipment with CH<sub>2</sub>O, Inc. products.

### INDUSTRIES

Field Irrigation	pH Adjustment
Commercial Disinfection	Commercial Potable Water
Livestock (dairy, horses, etc.)	

### TYPICAL APPLICATIONS

Clean and Flush	Commercial
Drip Irrigation	Irrigation Lines & Emitters
Livestock Water System	Water pH Adjustment

### PRODUCTS

Agri Guard Products	831
K-Plus	Oxy-Gone
Color Guard	Phos Trol F
Nitro-Clean	Unibrom Plus
Disolv-It	Disperse-It

### PREVENTATIVE MAINTENANCE (PM)

ITEM	FREQUENCY
Pump	Yearly Head Replacement
Check Valve	Replace, 6-12 Months
Back Pressure Valve	Inspect Monthly, Replace as Required
Injector Check Valve	Inspect Monthly, Replace as Required

### Seller Warranty

CH<sub>2</sub>O brand test reagent refills are available through your sales representative at no charge. Customers are required to confirm product compatibility via a control test for their specific application. CH<sub>2</sub>O recommends that you perform regular/daily testing to control chemical levels and cycles of concentration within established limits. Additional tests may be performed at your request. Test reports reflect conditions at the point when the analysis was performed. Results will change over time and with varying operating conditions.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the directions for use when used in accordance with the directions under normal conditions. Buyer assumes the risk of any use contrary to such directions. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

Applies to all products sold by CH<sub>2</sub>O, Inc., and is hereby communicated to all of its customers as a condition of sale. Use of CH<sub>2</sub>O products is subject to the Standard Terms and Conditions as listed on CH<sub>2</sub>O, Inc.'s website at: [www.ch2o.com](http://www.ch2o.com).



VERSION DATE: June 12, 2017

REVISION DATE:

