



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on July 22, 2015.

CH2O, Inc.
8820 Old Highway 99 Southeast
Olympia, WA 98501
800-445-0450
360-943-6063

Facility: Olympia, WA

Chemical/ Trade Designation	Function	Max Use
Blended Corrosion Inhibitor		
PHOS TROL F	Corrosion & Scale Control Sequestering	25 mg/L
Hydrochloric Acid		
Activator DW	Corrosion & Scale Control pH Adjustment	80 mg/L
Miscellaneous Chemical Products		
Sea Fresh [CL]	Oxidant	150 mg/L
Miscellaneous Treatment Chemical		
Aqua Clean 100	Reverse Osmosis Antiscalant	70 mg/L
Sodium Chlorite [CL]		
Aqua-Clear 15	Disinfection & Oxidation Oxidant	35 mg/L
Freeze Fresh 15	Oxidant	35 mg/L
IVR-SAN 15	Disinfection & Oxidation Oxidant	35 mg/L
IVR-SAN 7.5	Disinfection & Oxidation	70 mg/L

[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.