



8820 Old Hwy 99 SE, Tumwater, Washington 98501, USA
 360-943-6063 800-562-6184 FAX 360-352-4813 www.ch2o.com

**Public
 OEM
 Bulletin**

pH (Silver)



HISTORY

The PH (Silver) Unit has been designed to consistently and efficiently deliver the desired dosage of CH₂O, Inc. products listed in the PRODUCTS table. More information about our products and equipment is available at www.CH2O.com.

OPERATIONAL CONSIDERATIONS

Electric Needs: 110V
 Unit Dimensions: 18" wide x 18" high

The PH (Silver) comes equipped with a Flow switch. This allows the unit to supply product based on the flow switch in a contact on or off setting.

TESTING REQUIREMENTS

Testing can include pH, Chlorine Dioxide, Total Oxidants, and ORP levels to determine that desired system dosage is maintained for specific applications. A control test is necessary on individual plant species and/or applications to determine tolerance. Customers shall set treatment levels based on their control test results. Daily testing is recommended to maintain desired level control. It is the customer's responsibility to monitor and maintain treatment levels. Failure to monitor and maintain treatment levels can cause damage. Use only CH₂O, Inc. OEM equipment with CH₂O, Inc. products.

INDUSTRIES

Field Irrigation	Commercial Disinfection
Commercial Potable Water	pH Adjustment
Livestock (dairy, horses, etc.)	

TYPICAL APPLICATIONS

Drip Irrigation	Clean and Flush
Irrigation Lines & Emitters	Commercial Water Treatment
Livestock Watering System	Water pH Adjustment

PRODUCTS

AgriGuard	AgriPhuric
Bleach	K Plus
Sure Flow F	

PREVENTATIVE MAINTENANCE (PM)

ITEM	FREQUENCY
Pump	Yearly Diaphragm replacement
Back Pressure Valve	Inspect Monthly, Replace as Required
Injector Check Valve	Inspect Monthly, Replace as Required

Seller Warranty

CH₂O brand test reagent refills are available through your sales representative at no charge. Customers are required to confirm product compatibility via a control test for their specific application. CH₂O recommends that you perform regular/daily testing to control chemical levels and cycles of concentration within established limits. Additional tests may be performed at your request. Test reports reflect conditions at the point when the analysis was performed. Results will change over time and with varying operating conditions.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the directions for use when used in accordance with the directions under normal conditions. Buyer assumes the risk of any use contrary to such directions. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

Applies to all products sold by CH₂O, Inc., and is hereby communicated to all of its customers as a condition of sale. Use of CH₂O products is subject to the Standard Terms and Conditions as listed on CH₂O, Inc.'s website at: www.ch2o.com.



VERSION DATE: June 6, 2017

VERSION DATE:

