



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI/CAN 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on September 1, 2020.

CH2O, Inc.
8820 Old Highway 99 Southeast
Olympia, WA 98501
800-445-0450
360-943-6063

Facility: Olympia, WA

Chemical/ Trade Designation	Function	Max Use	
Blended Corrosion Inhibitor			
PHOS TROL F	Corrosion & Scale Control Sequestering	25	mg/L
Hydrochloric Acid			
Activator DW	Corrosion & Scale Control pH Adjustment	80	mg/L
Miscellaneous Chemical Products			
Sea Fresh ^[CL]	Oxidant	150	mg/L
Miscellaneous Treatment Chemical			
Aqua Clean 100	Reverse Osmosis Antiscalant	70	mg/L
Miscellaneous Water Supply Products			
AGRI GUARD FW ^[1]	Well Cleaning Aid	NA	
Well Done ^[1]	Well Cleaning Aid	NA	
Sodium Chlorite^[CL]			
Aqua-Clear 15	Disinfection & Oxidation Oxidant	35	mg/L
Freeze Fresh 15	Oxidant	35	mg/L
IVR-SAN 15	Disinfection & Oxidation Oxidant	35	mg/L
IVR-SAN 7.5	Disinfection & Oxidation	70	mg/L
Sodium Silicate			
831	Corrosion Control	42	mg/L

[1] This product is designed to be used off-line and flushed out prior to using the system for drinking water, following manufacturer's use instructions.

[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

1 of 1