



8820 Old Hwy 99 SE, Tumwater, Washington 98501, USA  
360-943-6063 800-562-6184 FAX 360-352-4813 www.ch2o.com

**Product  
Bulletin**

# GLYCOL INHIBITOR Water Treatment Additive

### TYPICAL APPLICATIONS

**GLYCOL INHIBITOR** may be used to augment the corrosion inhibition package of many commercially available glycol formulations. The product is a phosphate-based package which does not contain any specific yellow metal corrosion inhibitors.

### DIRECTIONS

Add **GLYCOL INHIBITOR** from the container into the system water where mixing will occur. Prior to addition of this product, it is strongly recommended that compatibility be evaluated by proportionally mixing with a small sample and observing the effects for a minimum of 24 hours.

### DOSE RATE

One gallon of **GLYCOL INHIBITOR** in 1,000 gallons of water will increase the phosphate levels by approximately 350 ppm. This dose rate may be increased or decreased as necessary to maintain the desired phosphate residual.

### SAFETY & HANDLING PROCEDURE

This product is a mild irritant. Safety glasses and impervious gloves should be worn when handling the concentrated product. Read Safety Data Sheet for further information.

### PHYSICAL PROPERTIES

Appearance ..... Clear Liquid  
Odor..... Mild  
Foam..... None  
Flash Point..... >200°F  
Pounds per Gallon ..... 12.6 – 13.1

### **Seller Warranty**

CH<sub>2</sub>O brand test reagent refills are available through your sales representative at no charge. Customers are required to confirm product compatibility via a control test for their specific application. CH<sub>2</sub>O recommends that you perform regular/daily testing to control chemical levels and cycles of concentration within established limits. Additional tests may be performed at your request. Test reports reflect conditions at the point when the analysis was performed. Results will change over time and with varying operating conditions.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the product data sheet. Buyer is responsible to ensure that products and product dosages are appropriate for Buyer's particular application. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

Applies to all products sold by CH<sub>2</sub>O, Inc., and is hereby communicated to all of its customers as a condition of sale. Use of CH<sub>2</sub>O products is subject to the Standard Terms and



VERSION DATE: October 21, 2016

