

OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI/CAN 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on December 8, 2023.

CH2O, Inc. 8820 Old Highway 99 Southeast Olympia, WA 98501 800-445-0450 360-943-6063

Facility: Olympia, WA

Chemical/ Trade Designation	Function		Max Use
Blended Corrosion Inhibitor			
PHOS TROL F	Corrosion & Scale Control	25	mg/L
	Sequestering		
Hydrochloric Acid			
Activator DW	Corrosion & Scale Control	80	mg/L
	pH Adjustment		
Miscellaneous Chemical Products			
Sea Fresh ^[CL]	Oxidant	150	mg/L
Miscellaneous Treatment Chemical			
Aqua Clean 100	Reverse Osmosis Antiscalant	70	mg/L
Miscellaneous Water Supply Products			
AGRI GUARD FW ^[1]	Well Cleaning Aid	NA	
Well Done ^[1]	Well Cleaning Aid	NA	
Sodium Bisulfite			
FILTRON DC ^[2]	Dechlorinator & Antioxidant	29	mg/L
Sodium Chlorite ^[CL]			
Aqua-Clear 15	Chlorine Dioxide Production	35	mg/L
	Oxidant		
Freeze Fresh 15	Oxidant	35	mg/L
IVR-SAN 15	Chlorine Dioxide Production	35	mg/L
	Oxidant		
IVR-SAN 7.5	Chlorine Dioxide Production	70	mg/L
Sodium Silicate			
831	Corrosion Control	42	mg/L

- [1] This product is designed to be used off-line and flushed out prior to using the system for drinking water, following manufacturer's use instructions.
- [2] This product contains sulfite. Sulfites have been known to cause potentially lethal allergic reactions in sulfite-sensitive individuals. The maximum recommended allowable residual sulfite level in the finished drinking water is 100 ppb (0.1 mg/L).
- [CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.